

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

**EN 62271-  
100:2009/A2:2017/AC:2018-  
03**

March 2018

---

ICS 29.130.10

English Version

**High-voltage switchgear and controlgear - Part 100: Alternating-  
current circuit-breakers  
(IEC 62271-100:2008/A2:2017/COR1:2018)**

Appareillage à haute tension - Partie 100: Disjoncteurs à  
courant alternatif  
(IEC 62271-100:2008/A2:2017/COR1:2018)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil  
100: Wechselstrom-Leistungsschalter  
(IEC 62271-100:2008/A2:2017/COR1:2018)

This corrigendum becomes effective on 9 March 2018 for incorporation in the English language version of the EN.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels**

### **Endorsement notice**

The text of the corrigendum IEC 62271-100:2008/A2:2017/COR1:2018 was approved by GENELEC as EN 62271-100:2009/A2:2017/AC:2018-03 without any modification.

INTERNATIONAL ELECTROTECHNICAL COMMISSION  
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

---

**IEC 62271-100:2008/AMD2:2017**  
Edition 2.0 2017-06

**IEC 62271-100:2008/AMD2:2017**  
Édition 2.0 2017-06

**HIGH-VOLTAGE SWITCHGEAR AND  
CONTROLGEAR –**

**APPAREILLAGE A HAUTE TENSION –**

**Part 100: Alternating-current circuit-breakers**

**Partie 100: Disjoncteurs à courant  
alternatif**

## **CORRIGENDUM 1**

### **6.104.5.4 Test-duty T30**

*Add, after item a) as modified by  
Amendment 2, the following new text:*

In case that small values of time  $t_3$  cannot be met, the shortest time that can be met shall be used. The values used shall be stated in the test report.

### **6.104.5.4 Séquence d'essais T30**

*Ajouter, après le point a) modifié par  
l'Amendement 2, le nouveau texte suivant:*

Si de petites valeurs du temps  $t_3$  ne peuvent pas être satisfaites, la durée la plus courte pouvant être satisfaite doit être utilisée. Les valeurs utilisées doivent être consignées dans le rapport d'essai.